

Technical Report Proven In Use – Series 8000

Client: Klay Instruments B.V.

Nijverheidsweg 5

7991 CZ Dwingeloo, The Netherlands

Products: Series 8000 and Hydrobar, Pressure and Level Transmitter

Number: 639.160.1

Revision: 1

Date: 2013-09-19

Author(s): W. Velten-Philipp

Risknowlogy Germany GmbH

Unterreit 6

76135 Karlsruhe

Germany

www.risknowlogy.com

© 2002 - 2013 Risknowlogy GmbH

All Rights Reserved

LIMITATION OF LIABILITY - This report was prepared using best efforts. Risknowlogy does not accept any responsibility for omissions or inaccuracies in this report caused by the fact that certain information or documentation was not made available to us. Any liability in relation to this report is limited to the indemnity as outlined in our Terms and Conditions. A copy is available at all times upon request.

Printed in Switzerland

This document is the property of, and is proprietary to Risknowlogy®. It is not to be disclosed in whole or in part and no portion of this document shall be duplicated in any manner for any purpose without Risknowlogy's expressed written authorization.

Risknowlogy®, the Risknowlogy logo®, Functional Safety Data Sheet®, and Spurious Trip Level® are registered service marks of Risknowlogy, STL™ is a Risknowlogy trademark.

Revisions

Revision	Date	Who	Description
0	2013-09-16	WVP	draft
1	2013-09-19	WVP	release

Table of Contents

Revisions	3
Table of Contents.....	4
List of Tables	5
List of Figures	5
Terms and Definitions	6
1 Introduction	7
1.1 Objective	7
1.2 About Klay Instruments	7
1.3 About Risknowlogy.....	7
2 Product Description.....	8
2.1 Introduction	8
3 Proven In Use Demonstration	10
3.1 Restricted Functionality	10
3.2 Conditions Of Use	10
3.3 Field Data.....	10
3.4 Modifications	10
3.5 Reliability analysis (FMEDA)	10
3.6 EMC, Basic safety and environmental testing	12
4 User Documentation	12
5 Conclusions	12
6 References.....	13

List of Tables

Table 1 – Operating hours and failures	10
Table 2 – Functional safety data for Series 8000	11
Table 3 – PFDavg calculation results (1oo1).....	11

List of Figures

Figure 1 – Series 8000 and Hydrobar, Pressure and Level Transmitter	8
Figure 2 – PFDavg results	12

Terms and Definitions

Term	Definition
Dangerous failure	An internal failure that prevents the product from carrying out its safety function upon demand. See also safe failure
Detected failure	An internal failure that is detected by built-in diagnostics. Because of the diagnostics the product can act upon the failure. See also undetected failure
FMEDA	Failure mode, effects and diagnostics analysis
Functional safety	A product is functionally safe if random, systematic and common cause failures do not lead to malfunctioning of the system and do not result in injury or death of humans, spills to the environment, or loss of equipment or production
Hardware fault tolerance	Hardware fault tolerance indicates the number of failures the product or subsystem can withstand without losing the safety function
HFT	See hardware fault tolerance
PFD	The probability that the safety function has failed upon demand
PFS	The probability that the safety function causes a spurious trip of the process
Safe failure	An internal failure where a product carries out its safety function without a demand from the process. This failure can lead to a spurious trip. See also dangerous failure
Safety function	Function implemented in the product required to achieve a safe state of the process
SFF	Safe failure fraction
SIL	Safety Integrity Level
STL	Spurious Trip Level [®]
Type	The complexity of a product is designated by Type A or Type B. See IEC 61508, part 2, clause 7.4.3.1.2 and 7.4.3.1.3
Undetected failure	An internal failure that is not detected by built-in diagnostics. See also detected failure

1 Introduction

1.1 Objective

The objective of this report is to document the proven in use study carried out for the Klay Series 8000 and Hydrobar pressure and level transmitters. This series of transmitters is available in many different process connections.

The purpose of the proven in use study is to demonstrate that the device is suitable to be used in safety instrumented functions up to SIL 2 according to IEC 61511 and IEC 61508 [1,2].

Note: According to IEC 61511, 11.4.4 SIL3 is possible in 1oo2 configuration in conjunction with prior use experience of the instrument user.

1.2 About Klay Instruments

Klay Instruments is a Dutch manufacturer of Process Instrumentation. Founded in 1978 Klay has build up a long history in development and production of process instrumentation. Klay produces a wide range of pressure and level transmitters in stainless steel design.

1.3 About Risknowlogy

Risknowlogy is an international operating company that offers services, consulting, certification and training in the field of risk, reliability and safety. Risknowlogy was established in 2002 and has offices in Switzerland, Argentina, Columbia, Germany, The Netherlands and United Arab Emirates. We consider the world as our work area and each location has obliged to maintain the same quality standards, rules, and business practices.

The headquarters of the Risknowlogy Corporation is located in Switzerland. Here we perform certification, business development, market our products and services, create new products and services, train our employees and service any country in the world that is not serviced by a local organization.

2 Product Description

2.1 Introduction

The product subject to the proven in use analysis is the Klay Series 8000 pressure transmitter.

Examples from the product are shown in Figure 1.



Figure 1 – Series 8000 and Hydrobar, Pressure and Level Transmitter

The functional safety properties according to IEC 61508 are:

- Safety function:
Measurement of absolute and relative pressure or level within the specified safety accuracy of 0.2 % from full span.
- The safety function response time is 50 ms.
- This is a type A device with hardware fault tolerance 0.
- The operation mode is low demand mode.

The conditions of use and constraints are described by the safety manual [8].

The end user is responsible for the validation of the safety function.

The following tables shows the suitable Series 8000 types:

Type	Number
Series 8000	8000-range-xx-xx
Series 8000-SAN	8000-SAN-range-xx-xx
Series CER-8000	CER-8000-range-xx-xx
Series Hydrobar Cable	Hydrobar-Cable(..m)-xx-xx
Series Hydrobar Cable (FR)	Hydrobar-Cable-FR(..m)-xx-xx

From serial number 10509426.

3 Proven In Use Demonstration

3.1 Restricted Functionality

The purpose of the transmitter is to measure the pressure and to transmit this pressure as a 4-20 mA signal. The functionality is restricted to pressure and hydrostatic level related measurements.

3.2 Conditions Of Use

The instrument considered for proven in use have been used in widely in the process industry in different operating environments [5]. These include more than 10 typical industrial process environments [4].

3.3 Field Data

Klay Instruments collected field data for the Series 8000 since production start. For the proven in use demonstration the field feedback since 2007 is taken into account [5]. From the operating hours of each instrument 6 month have been taken into account to exclude non-operating hours (e.g. from storage times, non-operation, etc). The typical operating time in the process industry is assumed 24 hours per day. Klay Instruments has compiled customer feedback and repair data [5] into data bases. The summarised data demonstrates that during the time under consideration 37 random failures occurred which were classified as dangerous failures due to the lag of further information (see Table 1).

Table 1 – Operating hours and failures

Type	Operating hours	Safe Failures	Dangerous Failures
Series 8000	985 127 700 h	-	37

3.4 Modifications

During the time span used for the proven in use demonstration the products were not subject to modifications.

3.5 Reliability analysis (FMEDA)

The reliability study consists of a failure modes and effects analyses (FMEDA) [6] and the estimation of the average probability of failure on demand of the safety function. The FMEDA was carried out in line with the requirements of the IEC 61508 [1] standard. Table 2 presents a summary of the reliability data derived from the FMEDA and the failure rates calculated from the field data taking a confidence interval of 90% into account.

Figure 2 shows the PFD and PFDavg curve (20 years).

The FMEDA analysis, which represents design expectations, corresponds with the data from the proven in use data, which represents operational experience.

Table 2 – Functional safety data for Series 8000

Properties	FMEDA	Proven In Use	90% Confidence (upper limit)
Type	A		
Safe failure rate	104	---	---
Safe detected failure rate	0	n.a.	n.a
Safe undetected failure rate	104	n.a.	n.a
Dangerous failure rate	36.4	37.6	49.4
Dangerous detected failure rate	0	n.a.	n.a
Dangerous undetected failure rate	36.4	n.a.	n.a
DC	0%	n.a.	n.a
Safe failure fraction	74%	n.a.	n.a

Notes:

- Failure rates in FIT [10^{-9} 1/h]
- Confidence interval according to IEC 61508 route 2_H

Table 3 – PFDavg calculation results (1oo1)

T1[a]	1	5	10	15	20
PFDG	1,62E-04	7,99E-04	1,60E-03	2,39E-03	3,19E-03
%SIL2	1,62%	7,99%	15,96%	23,93%	31,90%

MTTR 72h
 PFSavg is 4.52E-4.




Figure 2 – PFDavg results

3.6 EMC, Basic safety and environmental testing

The product complies [9] to

- EMC directive 2004/108/EC
- ATEX directive 94/9/EC

4 User Documentation

The safety manual [8] provided by Klay Instruments provides all necessary information for use of the product. The manual was reviewed without any objections.

5 Conclusions

The proven in use analysis demonstrates that the specified safety function of the Series 8000 pressure transmitters are suitable for SIL 2 safety properties according to IEC 61508, route 2_H and IEC 61511.

6 References

The following references have been used during the project:

1. IEC 61508: 2010
Functional Safety of Electrical, Electronic, Programmable Electronic Safety Related Systems
2. IEC 61511: 2003
Functional safety: Safety instrumented systems for the process industry sector
3. SN 29000, Failure Rates of Components, 2004
4. Applications 8000 series SIL
5. SIL-Repair-2007
SIL-Repair-2008
SIL-Repair-2009
SIL-Repair-2010
SIL-Repair-2011
Fieldfeddb_8000.xls
6. FMEA-Klay_8000_WVP_2013-09-11.xls
7. Schematics, Drawings
01001.docx
01002.docx
01003.docx
01004.docx
04009.docx
04010.docx
04011.docx
04012.docx
8. Manual, Safetymanual: SM-EN-8000/09-13/01
9. EMC, Environmental and basic safety
ATEX DEKRA (KEMA) Certificate 03ATEX1219X
Bureau Veritas Certificate 09165/C0 BV
DNV Certificate A-13344
EMC-Series-Hydrobar-cable-VM v1-1
EMC-test-Series CER-8000-D-N v1-1
EMC-test-Series-8000-SAN V1