

CERTIFICATE

NR. 28T 01 001

Technical Instruction on Air Quality Control Nr. 3.1.8.4 (TA-Luft)

We hereby certify that the below listed item has been tested according to:

I.Allgemeine VwV zum Bundes-Immissionsschutzgesetz (BImSchG) with satisfactory result.

Company:

PARCOL s.p.a.

Address:

CANEGRATE - ITALY

Valve type:

RISING STEM VALVE STEM PACKING GFE

Seal type: Valve rating:

150 ÷ 2500

Drawing: Test procedure: I-CPI5T rev. I MR / 950 rev.2

Report:

SPS/0002/01 issued by OMECO dtd. January 10, 2001

The required tightness was achieved on a representative valve at 25bar internal pressure and 350 °C valve temperature after 50000 cycles.

Busto Arsizio -VA- : January 15, 2001

RWTÜV Italian Branch



CERTIFICATE

Technical Report:

N.AW-SVA/137/98

Manufacturer:

Parcol S.p.A. Via Isonzo 2

I-20010 Canegrate (Mi)

Subject:

sealing device "Parcol TFG" packing type

The above device was submitted to helium leak test and, in our opinion, the same satisfies the specifications and requirements provided by the item 3.1.8.4 of TA Luft standard of 27.02.1986.

The validity range and all the test details are defined in the technical report.

Mannheim, 19th May 1998 AW-SVA-MAN Jo/Ks

TÜV BAYERN HESSEN SACHSEN SÜDWEST E.V. Systems Safety and Inlets Control Department Operating systems division

Dip).-Ing. John