



# Sintrol Snifter A2 EX

## Manual

Version 1.2.3

## Table of Contents

<b>1</b>	<b>INTRODUCTION.....</b>	<b>3</b>
1.1	Safety.....	3
1.2	Product overview.....	4
1.3	How does it work? .....	4
<b>2</b>	<b>INSTALLATION.....</b>	<b>4</b>
2.1	Selecting the installation location .....	4
2.2	Installing the sensor .....	6
<b>3</b>	<b>WIRING .....</b>	<b>7</b>
<b>4</b>	<b>TECHNICAL SPECIFICATION .....</b>	<b>8</b>
<b>5</b>	<b>DIMENSIONS.....</b>	<b>10</b>
<b>6</b>	<b>OPERATION .....</b>	<b>11</b>
6.1	The alarm threshold factory setting values:.....	11
<b>7</b>	<b>ADJUST PARAMETERS.....</b>	<b>13</b>
7.1	Signal averaging time .....	13
7.2	Alarm level settings.....	13
7.3	Alarm delay time.....	13
7.4	Alarm hysteresis time.....	13
<b>8</b>	<b>AUTOMATIC SETUP .....</b>	<b>14</b>
8.1	How to do the auto-setup? .....	14
<b>9</b>	<b>MAINTENANCE.....</b>	<b>15</b>
<b>10</b>	<b>TROUBLESHOOTING .....</b>	<b>15</b>
10.1	The Monitor is not giving output signal .....	15
10.2	The Monitor is not responding after auto-setup procedure.....	15
10.3	Boot check.....	15
<b>11</b>	<b>Appendix A: Sintrol PC software.....</b>	<b>16</b>
11.1	DustTool.....	16
	Preview .....	16
11.2	DustLog.....	19

## 1 INTRODUCTION

This manual describes how to install and use SINTROL's Snifter A2 EX dust monitor. Sintrol shall not be liable for any loss or damage whatsoever arising from use of any information or details therein, or omission or error in this manual, or any misuse of the product.

The instrument can be accessed by utilizing the DustTool Software.

The basic functionality of DustTool is to change the factory settings according to individual needs of the process.

Such functions for Snifter A2 EX are for example:

- Perform the auto-setup according to process typical dust levels.
- Change the Alarm Limits and the logic of signals.

The Software can be downloaded free of charge under the Sintrol web-site <http://www.sintrolproducts.com>

### 1.1 Safety

Snifter A2 EX requires 12 - 24 VDC power supply. Although these voltage levels are considered safe, the process gas or dust particulates can be hazardous to health.

The Snifter is designed for explosive environments fulfilling following ATEX and EX requirements. The sensor can be installed in EX and Atex zones 22.

IECEX VTT 14.0001X

Ex tc IIIB T 80°C Dc

Atex 22 VTT14 ATEX 001 X

CE  II 3 D  
EX tc IIIB T 80°C Dc



Take appropriate precautions when installing the monitor:

Unless the process conditions are known to be entirely safe, suitable precautions must be taken before any entry is made into the duct for installation or maintenance purposes.

- The unit may be installed in ducting, containing particulate, hazardous to health.

- The particulate may be inflammable, explosive or toxic
- The gas can be hot and pressurised

### *1.2 Product overview*

The Snifter A2 EX Dust monitor is a microprocessor-based, self-adjusting device, equipped with two independent and fully adjustable alarm signal and back light illuminated front cover.

Device is designed for filter bag leak detection. It can also be used to detect blockage or stoppage in pneumatic transport and bulk solids handling. It is a compact unit with the sensor and control electronics built into one IP65 enclosure, which has been specifically designed for easy installation and operation.

### *1.3 How does it work?*

The Snifter A2 EX uses Sintrol's proven and reliable inductive electrification technology where the interaction of particles with the sensor rod causes a small electrical charge to pass between the particulate and sensor.

It is this small electric charge that provides the signal monitored by the electronics, the signal generated is proportional to the dust level even if particles accumulate on the sensor. Experience has shown that this method of monitoring dust level in gasses, offers accurate results with minimum maintenance.


## **2 INSTALLATION**

### *2.1 Selecting the installation location*

The best location for installation is in a section of duct where the particulate has an even distribution and the flow is as laminar as possible. This is to ensure that the sensor rod comes into contact with a representative flow of particles.

The ideal position would be in a section of duct that has no bends, valves, dampers or other obstructions for a distance equal to at least three duct diameters downstream or upstream (preferable 5 x duct diameter).

Description of installation is presented in Figure 1 Recommended distance to duct bends (D = Duct diameter).



**Figure 1 Recommended distance to duct bends (D = Duct diameter)**

In some applications, a compromise must be made and the sensor will have to be fitted in a position that satisfies the majority of above requirements. The Snifter A2 EX must be attached to metal ductwork so that the device will be electrically shielded from interference and has good ground reference.

1. The unit shall be installed in a position, where the gas flow passes the sensor rod in a 90° angle.
2. In round cross-section ducts, the unit can be installed in any position above the horizontal axis (between 9 o'clock and 3 o'clock). See Figure 2
3. For square cross-section ducts, the unit must be positioned in the middle of the top or in the middle of one of the sides. See Figure 3
4. Although the sensor is not affected by vibration, very high vibration levels should be avoided.
5. The units must not be installed in direct sunlight or in areas where the ambient temperature is above +40 °C.

The unit above  
horizontal axis




Figure 2 Round cross section duct




Figure 3 Square cross section duct

#### NOTE

The sensor must not contact the opposite wall or any other obstacle inside the duct. The only allowed interaction with sensor is dust particles.

## 2.2 *Installing the sensor*

Once the location of the unit has been selected, the Snifter A2 EX with NPT 1/2" male thread can be installed to process with 1/2" female thread. Make sure the installation is in the right position, insert the sensor inside the adapter and rotate the Snifter until the connection is tight.

#### NOTE

Do not over tighten the Snifter A2 EX with process connection - It may cause damage to sensor and electronics.

### 3 WIRING

The Snifter A2 EX comes with two meter power and signal cable. There are 10 wires in the same cable, two wires for VDC power source, two for alarm signals, and one for automatic setup signal. Remaining wires are left for digital communication with Sintrol Dustlog software.

Connect the VDC power supply to pink (+) and GND to gray (-) wires. Blue and red wires are for alarm signals and they give the same voltage levels as power input voltage, when the alarm latches to high state.

PCB pin	Wire colour	Signal name
1	BLUE	Alarm signal 1
2	RED	Alarm signal 2
3	-	-
4	-	-
5	GRAY	V- (GND)
6	PINK	V+ (VDC)
7	GREEN	Automatic setup
8	BROWN	RS 485 D+
9	WHITE	RS 485 D-
10	BLUE/RED	USB DM
11	GRAY/PINK	USB DP
12	VIOLET	USB VBUS

**Table 1 Wiring and signals**

Snifter A2 EX can be powered by using only USB connection for the purpose of accessing and adjusting parameters with appropriate Sintrol PC software. More information about parameter adjustment can be found in section 7 of this manual.

## 4 TECHNICAL SPECIFICATION

Product name	Snifter A2 EX
Measurement Objects	Solid particles in a gas flow
Particle Size	0.3 $\mu\text{m}$ or larger
Measurement Range	From 0.1 $\text{mg}/\text{m}^3$
Measurement Principle	Inductive Electrification
Protection Category	IP65
Sensor Length (total/measuring)	250 mm / 185 mm
Power Supply	12-24 VDC
Power Consumption	3 W
Cable Connection	2 meter cable, 12 wires
Process Connection	NPT 1/2" male thread
Output Signals	<ul style="list-style-type: none"> <li>• Two output signals (100 – 280 mA)</li> <li>• Back light illuminated front cover</li> </ul>
Communication Interface	<ul style="list-style-type: none"> <li>• Serial communication RS-485</li> <li>• USB</li> <li>• Radio frequency (RF) (optional)</li> </ul>
Communication Protocol	<ul style="list-style-type: none"> <li>• Modbus RTU (RS-485)</li> <li>• SNT network (USB, RF and RS-485)</li> </ul>
Alarm settings	<ul style="list-style-type: none"> <li>• Set automatically by auto-setup based on average measured dust flow: 5 times and 20 times of reference dust flow.</li> <li>• User selectable</li> </ul>
Signal Averaging Time	<ul style="list-style-type: none"> <li>• Default at factory, 100 s</li> <li>• Adjustable from 0 – 6000 s</li> </ul>

Alarm delay time	<ul style="list-style-type: none"> <li>• Default at factory, 30 s</li> <li>• Adjustable from 0 – 60 000 s</li> </ul>
Alarm hysteresis time	<ul style="list-style-type: none"> <li>• Default at factory, 0s</li> <li>• Adjustable from 0 – 25 s</li> </ul>

#### Process Conditions

Temperature	Max 250 °C
Pressure	Max 200 kPa
Gas Velocity	Min 3 m/s
Humidity	Max 95 % RH (non-condensing)

#### Ambient Conditions


Starting temperature	-20...+40 °C
Running temperature	-40...+60 °C
Humidity	Max 95 % RH (non-condensing)

#### Materials and Weight

Probe (wetted part)	Stainless steel (AISI 316L)
Process Connection (wetted part)	Stainless steel (AISI 316L)
Enclosure	Aluminum
Probe Insulation (wetted part)	PEEK
Weight	0.6 kg

**Table 2 Technical specification**

## 5 DIMENSIONS



**Figure 4 Structure and dimensions**

This instrument conforms to the following standards

	<p>Product standard - electrical equipment for measurement, control and laboratory use – EMC requirements</p>	<p>Reference standard IEC 61326-1:2005 (First Edition)</p>
---	---	--

## 6 OPERATION

The Snifter A2 EX Dust Monitor measures the dust level in a gas flow by using inductive electrification technology which is based on AC measurement of moving particles which carry a charge.

There are two alarm signal outputs to indicate two different alarm conditions. In addition to this, the front cover illumination will blink to inform about the current alarm condition.


### 6.1 The alarm threshold factory setting values:

Alert: > 5 times normal dust level (during automatic setup) = Limit 1 value

Alarm: > 20 times normal dust level (during automatic setup) = Limit 2 value

ALARM SIGNALS	DUST LEVEL	FRONT COVER ILLUMINATION	OPERATION
S1: LOW S2: LOW	-	OFF	Power OFF, failure or auto-setup failed
S1: LOW S2: HIGH	Dust level < Limit1	ON	Normal operation
S1: HIGH S2: LOW	Limit1 <= Dust level < Limit2	BLINKING COUNT IS ONE (B)	Alert
S1: HIGH S2: HIGH	Dust level >= Limit 2	BLINKING COUNT IS TWO (C)	Alarm

Table 3 Default operating configuration on factory settings



**Figure 5 Description of Snifter A2 EX cover illumination sequences.**

## **7 ADJUST PARAMETERS**

Since every industrial process is different Snifter A2 EX is designed so that parameters which are important to customer can be easily adjusted. Adjustment of parameters can be done by using USB, RS-485 or optionally with RF communication. Depending on the chosen communication method set to the device, the adjustments can be done either with Sintrol PC software or standard Modbus RTU master unit.

By default, the communication mode of the device is set to work with Sintrol PC software. To use MODBUS RTU communication, appropriate network parameters needs first to be set into the device.

### **7.1 *Signal averaging time***

Snifter A2 EX damping time has been adjusted to 100 seconds in factory but it can be adjusted freely between 0 seconds and 6000 seconds (1 h 30 min).

### **7.2 *Alarm level settings***

Default Snifter A2 EX alarm signal levels have been adjusted to 5 and 20 times, compared to the process dust level during the automatic setup. These parameters and signal logic can be adjusted freely to be any levels required by the customer's process monitoring demands.

### **7.3 *Alarm delay time***

It is possible to set delay time for Snifter A2 EX alarm signals to avoid false alarms caused by dust concentration peaks which appear naturally in process. On factory settings, alarm delay is set to 30 seconds but it can be adjusted freely between 0 and 60 000 seconds.

### **7.4 *Alarm hysteresis time***

Snifter A2 EX contains alarm hysteresis time parameter which sets the minimum frequency for alarm signal to change its stage. On a factory settings hysteresis time is set to 0 seconds but it can be set freely between 0 and 25 seconds.

## 8 AUTOMATIC SETUP

Snifter A2 EX has an automatic setup procedure. When this auto-setup procedure is initiated, it sets the dust measuring parameters based on the currently measured dust level.

As the auto-setup procedure can also be altered by the user, this section only describes the actions when the factory default auto-setup is run.

After the auto-setup, by default alarm signals are set as follows:

- alert when the dust concentration exceeds 5 times the typical dust level.
- alarm when the dust concentration exceeds 20 times typical dust level.

In addition, the following key parameters will also be affected.

- Dust signal averaging time is set to default.
- Signal hysteresis and delay times are set to default.

For more information, see Table 3 Default operating configuration on factory settings.

### 8.1 *How to do the auto-setup?*

Follow the procedure below to run the auto-setup.

1. Connect the sensor to the duct, connect the power to the device and wait for 10 minutes for the process to stabilize.
2. Then start the auto-setup procedure either:

2.1 by connecting the automatic setup signal (green wire) to the V+ signal (wire) for a period of 1 second. The automatic setup will initiate and the front panel light will start to blink slowly (sequence D in Figure 5 Description of Snifter A2 EX cover illumination sequences.).

Then Release the automatic setup signal, by disconnecting the green wire from V+.

2.2 or initiating auto-setup remotely using remote communication options.

Auto-setup procedure takes 10 times TC seconds ie. 1000 seconds (approx. 17 min) to complete. When the front cover lighting stops blinking, the auto-setup is finished and the Snifter A2 EX is ready for use.

## 9 MAINTENANCE

Snifter A2 EX dust monitor needs very little maintenance. To achieve maximum reliable operation the recommended maintenance interval is 2 months.

Maintenance is done by removing the unit from the process and cleaning the sensor rod to prevent signal leakage to ground. Opening the enclosure during the maintenance is not advised due to the warranty reasons.

If the particles in the gas are sticky and tend to build up, the cleaning needs to be done more often.

## 10 TROUBLESHOOTING

### 10.1 *The Monitor is not giving output signal*

- Check the power and signal wiring are connected correctly.
- Check there is power on (cover glows).
- Do the automatic setup procedure

If the monitor is not giving any output signal after checks 1, 2 and 3, contact your local distributor.

### 10.2 *The Monitor is not responding after auto-setup procedure*

- Check that there is normal process going on during auto-setup.
- Check the power and signal wiring are connected correctly.
- Check the signal is not leaking to ground.
  - There is NO contact between metal sensor probe and duct wall.
  - Ensure that the gas is not condensing (causes signal leakage).
  - Check the sticky dust does not build up on the base of the sensor and no bridging between sensor probe and duct wall.

#### **NOTE**

Front cover illumination sequence F is on (10 Hz rate), when signal leaking to the ground is permanent.

### 10.3 *Boot check*

If green wire for starting automatic setup is connected before 15 seconds has elapsed from the power ON, boot check is initiated. Test takes some seconds and it is indicated with a sharply blinking front cover illumination sequence E (1 Hz rate).

If test fails, sequence F is initiated (10 Hz rate).

## **11 Appendix A: Sintrol PC software**

All Sintrol products can be controlled with Sintrol PC software provided they have appropriate bus interface available.

### *11.1 DustTool*

DustTool is complementary software to help you to get easily control of the parameters and features of your Sintrol products.

The hardware requirements to run the software are:


- Windows XP, Vista or 7
- Screen resolution of 1024x768 pixels or more
- Minimum memory starting from 512 MB

The DustTool PC-software can be connected directly to the meters via USB. By using converter also connections over RS 485 and RF are supported.

#### **Preview**

When DustTool software opens it looks for USB-connected Sintrol products. In case any products are connected, they will appear within the software and can directly be managed.

The main view of the software is illustrated below.



The list of connected products and the connection type icon, lets you easily select the device you need to control.

Tab area to manage product related features, like device parameters, auto-setup controls and of course the monitor view to quickly provide you a clear visualization of the current process condition..

From the **settings view** you can have full control over software parameters, like network access and language selection.

**Help view** will give you direct access to the manuals and documentation related to devices currently connected.

In case you should allow the internet connections, DustTool would automatically access Sintrol Server's product database and provide you with the latest and printable documentation for your convenience.

No more missing manuals.

Product type (name) and the picture of the device at hand is always visible.

Info area on the bottom helps you all the time by giving actively information about a number of fields and items on screen. All you need to do, is to move mouse over the item, parameter or title you wish to know more about.

**Figure 6 DustTool main window**

On the parameters page, user can modify the operating parameters of the connected Dust meter. The basic operating principle to change parameters is:

1. Change parameter to the desired value
2. Press "Save" button to save the changes into the memory of the instrument. If the "Save" button is not pressed, the changes will not be sent to the device and the values will be lost at program shut down or when device is detached.
3. By pressing "Read", the parameters which are currently saved in the instrument will be loaded from the device.

On the monitor view of the DustTool software it is possible to follow online the dust levels. Monitor view is intended to help user in decision when setting up parameters manually.

In order to further save measurement data, create additional signals and alarms and/or generate reports and history, commercial DustLog software is required.




Figure 7 DustTool monitor view

## 11.2 *DustLog*

DustLog software starting from version 8, is commercial product intended to meet real time data acquisition, storage and reporting needs for all Sintrol products and a variety of applications. DustLog software covers all the easy to use features available in the complementary DustTool software.

We recommend the use of Dustlog software for:

- comprehensive data storage
- data export option to third party software (f.ex. MS Excel)
- measurement history and reporting functionality
- history based calibration actions
- offsite data storage into multiple supported database servers.
- in the need of real time virtual signals and alarms
- when setting up or managing the whole measurement networks of
  - multiple different instruments
  - multiple different physical connections (RF or wires) within the same installation.
- professional real time monitor views from a number of different measurement points with powerful visualization and grouping options.

A wide range of reports can be generated to see historical trends in the measurement with the ability to generate monthly, daily or hourly averages charted on self-explaining graphs. Additionally, the easy user interface gives the plant the full control of the device's parameters so they can be read, sent or configured directly from the control room. After installation of the monitor, all access to the monitor controls can be done remotely using the Dustlog 8.

Further information regarding functionalities and costs of DustLog 8 can be obtained by our local distributors or under <http://www.sintrolproducts.com>

**NOTES**

---

---


---

---

---

---

---



SINTROL Oy  
Ruosilantie 15  
00390 Helsinki  
Finland  
Tel +358 9 5617 360  
Fax +358 9 5617 3680  
[www.sintrolproducts.com](http://www.sintrolproducts.com)